

System Summary

Controller Details

| | |
|------------------|------------------------|
| Name: | MCRC Grand Prairie, TX |
| Location: | Grand Prairie, TX |
| Date: | 05-07-08 06:00:23 AM |

| Direct Sensors | Current Reading | Set Point | Last 24 Hrs | | |
|-------------------------|------------------|-----------|-------------|------|------|
| | | | AVG | MIN | MAX |
| Clean Water Tank PH(S1) | 7.99 pH 62.65 °F | N/A | 8.17 | 7.99 | 8.28 |

| Outputs | Output Status |
|-----------------------------------|---------------------|
| Clean Water Tank Makeup Valve(R1) | Off |
| Gigasorber precoat(R2) | Off |
| OWS Pump(R3) | Off |
| Low Air Pressure Alarm Relay(R4) | Off |
| Remote System On/Off(R5) | On, 1 days,01:26:53 |

| 4-20mA Inputs | Measure | Last 24 Hrs | | | Status | Total |
|--------------------------------------|--------------|-------------|--------|--------|--------|------------|
| | | AVG | MIN | MAX | | |
| Grand Prairie Outside Air Temp(AI_1) | 70.18 Temp | 71.80 | 62.61 | 80.11 | Normal | N/A |
| Gigasorber Pressure(AI_2) | 0.08 PSI | 0.09 | 0.03 | 0.14 | Normal | N/A |
| Gigasorber Flow(AI_3) | 0.00 gal/min | 0.00 | 0.00 | 0.00 | Normal | 796.98 gal |
| Grand Prairie Inside Air Temp(AI_4) | 68.05 Temp | 67.74 | 67.30 | 68.08 | Normal | N/A |
| System Air Pressure(AI_5) | 121.14 PSI | 121.55 | 121.17 | 121.94 | Normal | N/A |

Alarm Status

Clean Water Tank PH (S1) Calibration Time

| Digital Inputs | Input Type | Status |
|---|---------------|---------------------------------------|
| Sediment Pit HL(DI_A) | Generic Input | Sediment Pit Normal 1 days,01:27:00 |
| System Emergency Stop(DI_B) | Generic Input | System Operational 1 days,01:27:00 |
| Clean Water Tank Low Level Switch(DI_5) | Generic Input | Clean Water Normal 1 days,01:27:02 |
| OWS Oil Level(DI_6) | Generic Input | OWS Normal 1 days,01:27:00 |